











Depuratore di Merano / Kläranlage Meran

Valori di depurazione ottenuti nel mese di  
Reinigungswerte erhalten im Monat  
09.2021

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>954.635</b>
---	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	0,50	0,0	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	4,81	
BOD5 / BSB5	mg/l	25,00	3,50	
CSB / COD	mg/l	100,00	24,61	
NH4-N	mg/l	8,00	1,57	
NO3-N	mg/l	8,00***	1,56	
NO2-N	mg/l	0,60	0,30	
N-Tot / N-Gesamt	mg/l	10,00*	4,79	
P-Tot / P-Gesamt	mg/l	1,00**	0,32	

\*con concentrazione in ingresso < 50 mg/l \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>20	23,03	
---	---	-----------------------------------	-----	-------	---

CHIAMATE - ALLARMI ANRUFE - ALARME	
---------------------------------------	--

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.  
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.