



## Depuratore di Merano / Kläranlage Meran

Valori di depurazione ottenuti nell'anno  
Reinigungswerte erhalten im Jahr  
2022

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>9.605.845</b>
---	------------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	0,50	0,1	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	8,44	
BOD5 / BSB5	mg/l	25,00	4,78	
CSB / COD	mg/l	100,00	26,23	
NH4-N	mg/l	8,00	2,01	
NO3-N	mg/l	8,00***	2,49	
NO2-N	mg/l	0,60	0,13	
N-Tot / N-Gesamt	mg/l	10,00*	5,33	
P-Tot / P-Gesamt	mg/l	1,00**	0,48	

\*con concentrazione in ingresso < 50 mg/l \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>20	22,31	
---	---	-----------------------------------	-----	-------	--