













Depuratore di Merano / Kläranlage Meran

Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
07.2022

ACQUA TRATTATA / BEHANDELTES WASSER (mc)	900.672
---	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT	
Solidi sedimentabili Absetzbare Stoffe	ml/l	0,50	1,4 
Solidi sospesi totali Schwebestoffe	mg/l	35,00	11,67 
BOD5 / BSB5	mg/l	25,00	8,50 
CSB / COD	mg/l	100,00	29,50 
NH4-N	mg/l	8,00	3,60 
NO3-N	mg/l	8,00***	2,47 
NO2-N	mg/l	0,60	0,18 
N-Tot / N-Gesamt	mg/l	10,00*	7,11 
P-Tot / P-Gesamt	mg/l	1,00**	0,86 

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm		Valori ottimali optimale Werte	>20	22,82	
---	--	-----------------------------------	-----	-------	---

Consumo elettrico per AE Stromverbrauch pro EW	kWh/d	0,061
Indicatore di prestazione Leistungskennwert	-	2,02

CHIAMATE - ALLARMI ANRUFE - ALARME	
---------------------------------------	--

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.