











## Depuratore di Merano / Kläranlage Meran

Valori di depurazione ottenuti nel mese di  
Reinigungswerte erhalten im Monat  
**02.2023**

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>562.403</b>
---	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	0,50	0,0	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	6,50	
BOD5 / BSB5	mg/l	25,00	5,25	
CSB / COD	mg/l	100,00	22,13	
NH4	mg/l	8,00	1,76	
NO3-N	mg/l	8,00***	3,33	
NO2-N	mg/l	0,60	0,11	
N-Tot / N-Gesamt	mg/l	10,00*	5,28	
P-Tot / P-Gesamt	mg/l	1,00**	0,25	

\*con concentrazione in ingresso < 50 mg/l \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm		Valori ottimali optimale Werte	>20	21,53	
---	--	-----------------------------------	-----	-------	---

Consumo elettrico per AE Stromverbrauch pro EW	kWh/d	0,053
Indicatore di prestazione Leistungskennwert	-	0,94

CHIAMATE - ALLARMI ANRUFE - ALARME	
---------------------------------------	--

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.  
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.