










## Depuratore di Bolzano / Klaieranlage Bozen

Valori di depurazione ottenuti nell'anno  
Reinigungswerte erhalten im Jahr  
2021

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>15.437.286</b>
---	-------------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	0,50	0,18	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	6,77	
BOD5 / BSB5	mg/l	25,00	4,44	
CSB / COD	mg/l	100,00	22,83	
NH4-N	mg/l	8,00	0,78	
NO3-N	mg/l	8,00***	4,33	
NO2-N	mg/l	0,60	0,10	
N-Tot / N-Gesamt	mg/l	10,00*	6,25	
P-Tot / P-Gesamt	mg/l	1,00**	0,44	

\*con concentrazione in ingresso < 50 mg/l \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>24	25,30	
---	---	-----------------------------------	-----	-------	---