

Depuratore di Bolzano / Klaieranlage Bozen


Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
05.2021

| | |
|---|------------------|
| ACQUA TRATTATA / BEHANDELTES WASSER (mc) | 1.342.611 |
|---|------------------|

| PARAMETRO / PARAMETER | LIMITE/GRENZWERT | VALORE / WERT | | |
|---|------------------|---------------|-------|---|
| Solidi sedimentabili Absetzbare Stoffe | ml/l | --- | 0,01 |  |
| Solidi sospesi totali Schwebestoffe | mg/l | 35,00 | 3,95 |  |
| BOD5 / BSB5 | mg/l | 25,00 | 4,14 |  |
| CSB / COD | mg/l | 100,00 | 22,56 |  |
| NH4-N | mg/l | 8,00 | 0,97 |  |
| NO3-N | mg/l | 8,00*** | 4,17 |  |
| NO2-N | mg/l | 0,60 | 0,07 |  |
| N-Tot / N-Gesamt | mg/l | 10,00* | 5,88 |  |
| P-Tot / P-Gesamt | mg/l | 1,00** | 0,28 |  |

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

| | | | | | |
|---|---|-----------------------------------|-----|-------|---|
| Sostanza secca fango Trockensubstanz Schlamm | % | Valori ottimali optimale Werte | >24 | 24,75 |  |
|---|---|-----------------------------------|-----|-------|---|

| | | |
|---------------------------------------|----|---|
| CHIAMATE - ALLARMI ANRUFE - ALARME | 11 |  |
|---------------------------------------|----|---|

Numero di interventi di reperibilità al di fuori dell'orario di lavoro
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.