











Depuratore di Pontives / Kläranlage Pontives

Valori di depurazione ottenuti nell'anno
Reinigungswerte erhalten im Jahr
2022

ACQUA TRATTATA / BEHANDELTES WASSER (mc)	3.337.218
---	------------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	0,50***	0,9	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	7,62	
BOD5 / BSB5	mg/l	25,00	4,93	
CSB / COD	mg/l	100,00	22,7	
NH4-N	mg/l	8,00	2,73	
NO3-N	mg/l	12,00***	7,55	
NO2-N	mg/l	0,60	0,11	
N-Tot / N-Gesamt	mg/l	15,00*	11,3	
P-Tot / P-Gesamt	mg/l	2,00**	1,00	

*con concentrazione in ingresso < 50 mg/l e temperatura >= 12°C **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l und Wassertemperatur >= 12°C **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>22	23,4	
---	---	-----------------------------------	-----	------	---