











Depuratore di Pontives / Kläranlage Pontives

Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
07.2023

ACQUA TRATTATA / BEHANDELTES WASSER (mc)	531.549
-------------------------------------------------	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	2,5	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	5,04	
BOD5 / BSB5	mg/l	25,00	6,67	
CSB / COD	mg/l	100,00	21,0	
NH4	mg/l	8,00	2,2	
NO3-N	mg/l	12,00***	4,73	
NO2-N	mg/l	0,60	0,06	
N-Tot / N-Gesamt	mg/l	15,00*	7,5	
P-Tot / P-Gesamt	mg/l	2,00**	1,07	

*con concentrazione in ingresso < 50 mg/l e temperatura >= 12°C **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l und Wassertemperatur >= 12°C **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>22	24,1	
-------------------------------------------------	---	-----------------------------------	-----	------	---------------------------------------------------------------------------------------

CHIAMATE - ALLARMI prio 1 ANRUFE - ALARME prio 1	
CHIAMATE - ALLARMI prio 2 ANRUFE - ALARME prio 2	

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.

Temperatura Ingresso Zulauf Temperatur	13,9
-------------------------------------------	------