










## Depuratore di Pontives / Kläranlage Pontives

Valori di depurazione ottenuti nel mese di  
Reinigungswerte erhalten im Monat  
**06.2024**

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>337.185</b>
---	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	0,0	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	2,95	
BOD5 / BSB5	mg/l	25,00	3,42	
CSB / COD	mg/l	100,00	16,7	
NH4	mg/l	15,00	2,5	
NO3-N	mg/l	12,00***	4,95	
NO2-N	mg/l	0,60	0,16	
N-Tot / N-Gesamt	mg/l	15,00*	7,5	
P-Tot / P-Gesamt	mg/l	2,00**	0,64	

\*con concentrazione in ingresso < 50 mg/l e temperatura >= 12°C \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l und Wassertemperatur >= 12°C \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>22	24,5	
---	---	-----------------------------------	-----	------	---

CHIAMATE - ALLARMI prio 1 ANRUFE - ALARME prio 1	
CHIAMATE - ALLARMI prio 2 ANRUFE - ALARME prio 2	

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.  
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.

Temperatura Ingresso Zulauf Temperatur	10,8
---	------