










## Depuratore di Termeno / Klaieranlage Tramin

Valori di depurazione ottenuti nel mese di  
Reinigungswerte erhalten im Monat  
06.2021

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>262.428</b>
---	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	0,04	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	3,91	
BOD5 / BSB5	mg/l	25,00	4,78	
CSB / COD	mg/l	100,00	18,60	
NH4-N	mg/l	8,00	0,83	
NO3-N	mg/l	8,00***	3,04	
NO2-N	mg/l	0,60	0,06	
N-Tot / N-Gesamt	mg/l	10,00*	5,19	
P-Tot / P-Gesamt	mg/l	1,00**	0,39	

\*con concentrazione in ingresso < 50 mg/l \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>24	23,30	
---	---	-----------------------------------	-----	-------	---

CHIAMATE - ALLARMI prio 1 ANRUFEN - ALARME prio 1	
CHIAMATE - ALLARMI prio 2 ANRUFEN - ALARME prio 2	

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.  
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.