











Depuratore di Termeno / Klaieranlage Tramin

Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
02.2022

ACQUA TRATTATA / BEHANDELTES WASSER (mc)	171.757
---	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	0,01	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	4,58	
BOD5 / BSB5	mg/l	25,00	5,29	
CSB / COD	mg/l	100,00	21,68	
NH4-N	mg/l	8,00	1,18	
NO3-N	mg/l	8,00***	5,60	
NO2-N	mg/l	0,60	0,06	
N-Tot / N-Gesamt	mg/l	10,00*	7,31	
P-Tot / P-Gesamt	mg/l	1,00**	0,25	

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>24	22,34	
---	---	-----------------------------------	-----	-------	---

CHIAMATE - ALLARMI prio 1 ANRUFTE - ALARME prio 1	
CHIAMATE - ALLARMI prio 2 ANRUFTE - ALARME prio 2	

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.