











Depuratore di Termeno / Kläranlage Tramin

Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
07.2023

ACQUA TRATTATA / BEHANDELTES WASSER (mc)	327.259
-------------------------------------------------	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	0,00	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	6,09	
BOD5 / BSB5	mg/l	25,00	5,38	
CSB / COD	mg/l	100,00	23,00	
NH4	mg/l	8,00	1,06	
NO3-N	mg/l	8,00***	2,92	
NO2-N	mg/l	0,60	0,42	
N-Tot / N-Gesamt	mg/l	10,00*	5,12	
P-Tot / P-Gesamt	mg/l	1,00**	1,03	

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>24	22,39	
-------------------------------------------------	---	-----------------------------------	-----	-------	---------------------------------------------------------------------------------------

CHIAMATE - ALLARMI prio 1 ANRUFTE - ALARME prio 1	
CHIAMATE - ALLARMI prio 2 ANRUFTE - ALARME prio 2	

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.